





School District Type	School Name	SamplePointName (Source_Name)	Initial Result		Repeat Result		Confirmatory		2nd Confirmatory		For Confirmatory Level >15 ppb, Investigative Sample Result										Comments	
			Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample #2 Pb (µg/L)	Sample #3 Pb (µg/L)	Sample #4 Pb (µg/L)	Sample #5 Pb (µg/L)	Sample #6 Pb (µg/L)	Sample #7 Pb (µg/L)	Sample #8 Pb (µg/L)	Sample #9 Pb (µg/L)		Sample #10 Pb (µg/L)
SFUSD	Clarendon ES	Clarendon ES - Site A Clarendon ES - Site B Clarendon ES - Site C Clarendon ES - Site D Clarendon ES - Site E	5-Oct-17 5-Oct-17 5-Oct-17 5-Oct-17 5-Oct-17	< 1 < 1 < 1 < 1 < 1																		
SFUSD	Cleveland ES	Cleveland ES - Site A Cleveland ES - Site B Cleveland ES - Site C Cleveland ES - Site D Cleveland ES - Site E	5-Oct-17 5-Oct-17 5-Oct-17 5-Oct-17 5-Oct-17	< 1 < 1 < 1 < 1 < 1																		
SFUSD	Commodore Sloat ES	Commodore Sloat ES - Site A Commodore Sloat ES - Site B Commodore Sloat ES - Site C Commodore Sloat ES - Site D Commodore Sloat ES - Site E	11-Apr-17 11-Apr-17 11-Apr-17 13-Apr-17 11-Apr-17	< 1 < 1 < 1 < 1 1.4																		
SFUSD	Cooper (Sarah B) Children Center	Cooper (Sarah B) Children Center - Site A Cooper (Sarah B) Children Center - Site B Cooper (Sarah B) Children Center - Site C Cooper (Sarah B) Children Center - Site D Cooper (Sarah B) Children Center - Site E																				
SFUSD	Creative Arts Charter	Creative Arts Charter - Site A Creative Arts Charter - Site B Creative Arts Charter - Site C Creative Arts Charter - Site D Creative Arts Charter - Site E	13-Dec-17 13-Dec-17 13-Dec-17 13-Dec-17 13-Dec-17	< 1 < 1 1.4 1.5 < 1																		
SFUSD	D. Feinstein ES	D. Feinstein ES - Site A D. Feinstein ES - Site B D. Feinstein ES - Site C D. Feinstein ES - Site D D. Feinstein ES - Site E	27-Sep-17 27-Sep-17 27-Sep-17 27-Sep-17 27-Sep-17	< 1 < 1 < 1 < 1 < 1																		
SFUSD	Daniel Webster ES	Daniel Webster ES - Site A Daniel Webster ES - Site B Daniel Webster ES - Site C Daniel Webster ES - Site D Daniel Webster ES - Site E	20-Sep-17 20-Sep-17 20-Sep-17 20-Sep-17 20-Sep-17	< 1 < 1 < 1 < 1 4.14																		
SFUSD	Denman (James) Middle School	Denman (James) Middle School - Site A Denman (James) Middle School - Site B Denman (James) Middle School - Site C Denman (James) Middle School - Site D Denman (James) Middle School - Site E	19-Dec-17 19-Dec-17 19-Dec-17 19-Dec-17 19-Dec-17	< 1 < 1 < 1 < 1 < 1																		
SFUSD	Downtown HS	Downtown High School - Site A Downtown High School - Site B Downtown High School - Site C Downtown High School - Site D Downtown High School - Site E	5-Dec-17 5-Dec-17 5-Dec-17 5-Dec-17 5-Dec-17	43 < 1 2.5 49 < 1	12-Dec-17	36																
		Downtown High School - SPECIAL SAMPLE Downtown High School - SPECIAL SAMPLE Downtown High School - SPECIAL SAMPLE Downtown High School - SPECIAL SAMPLE Downtown High School - SPECIAL SAMPLE Downtown High School - SPECIAL SAMPLE Downtown High School - SPECIAL SAMPLE Downtown High School - SPECIAL SAMPLE Downtown High School - SPECIAL SAMPLE Downtown High School - SPECIAL SAMPLE	16-Dec-17 16-Dec-17 16-Dec-17 16-Dec-17 16-Dec-17 16-Dec-17 16-Dec-17 16-Dec-17 16-Dec-17 16-Dec-17	2.3 2.5 2.5 2.3 3.6 3.7 2 5.4 35 42	26-Jan-18	27	2-Feb-18	21														

CI strip used for repeat sample  
CI strip used for repeat sample































School District Type	School Name	SamplePointName (Source_Name)	Initial Result		Repeat Result		Confirmatory		2nd Confirmatory		For Confirmatory Level >15 ppb, Investigative Sample Result										Comments		
			Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample #2 Pb (µg/L)	Sample #3 Pb (µg/L)	Sample #4 Pb (µg/L)	Sample #5 Pb (µg/L)	Sample #6 Pb (µg/L)	Sample #7 Pb (µg/L)	Sample #8 Pb (µg/L)	Sample #9 Pb (µg/L)		Sample #10 Pb (µg/L)	
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	1.08																			<p>No flow during initial sampling on 10/28/17. Successfully sampled on 11/2.</p> <p>LF. 2 Sampling attempts on 11/1 and 11/9. No sample on both days. Tap capped as of 11/15; school district will call SFPUC when/if tap is repaired.</p> <p>No flow on 10/28. Sampling rescheduled and delivered on 11/1/2017</p>
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	4.66																			
		West Portal ES - SPECIAL SAMPLE	2-Nov-17	65.6	9-Nov-17	29.8					9-Nov-17	3.42	1.84	1.53	1.6	2.28	1.34	< 1	1.81	1.89			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	5.43																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	99.1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	1.07																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	1.1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	1-Nov-17	31.2	9-Nov-17	18.4																	
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	5.76																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	3.24																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	4.98																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	2.12																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	< 1																			
		West Portal ES - SPECIAL SAMPLE	28-Oct-17	4.79																			
SFUSD	Yick Wo ES	Yick Wo ES - Site A	11-Oct-17	< 1																		Principal preferred to sample one site only.	
		Yick Wo ES - Site B																				Site not indicated by school	
		Yick Wo ES - Site C																				Site not indicated by school	
		Yick Wo ES - Site D																				Site not indicated by school	
		Yick Wo ES - Site E																				Site not indicated by school	